



## Certificate of Conformity - Particle Size Distribution 2025

|                                    |   |
|------------------------------------|---|
| Site:                              | Sheehan Soil Washing Plant                        |
| Material Type:                     | 10/20 mm Washed Stone                             |
| Certificates of analysis included: | 25-007093-1, 25-020013-1, 25-039585 & 25-057152-1 |

|          |        |
|----------|--------|
| Date:    | Feb-26 |
| Version: | 1      |


| Particle Size (mm) | Average % Passing | Specification based on BS EN 12620: 2002+A1 2008 (10/20). | Pass/Fail |
|--------------------|-------------------|---|-----------|
| 500                | 100               |   |           |
| 300                | 100               |   |           |
| 125                | 100               |   |           |
| 80                 | 100               |   |           |
| 63                 | 100               |   |           |
| 40                 | 100               | 100 - 100   | PASS      |
| 31.5               | 100               | 98 - 100  | PASS      |
| 20                 | 92                | 85 - 99   | PASS      |
| 16                 | 51                |   |           |
| 14                 | 25                |   |           |
| 10                 | 2                 | 0 - 20  | PASS      |
| 8                  | 1                 |   |           |
| 6.3                | 1                 |   |           |
| 4                  | 1                 | 0 - 5   | PASS      |
| 2.8                | 1                 |   |           |
| 2                  | 1                 |   |           |
| 1                  | 1                 |   |           |
| 0.5                | 1                 |   |           |
| 0.25               | 1                 |   |           |
| 0.125              | 1                 |   |           |
| 0.063              | 0.5               |   |           |

|  |
|--|
| Non Engineering Description                |
| Multi-colour Gravel with brick and asphalt |

|   |
|---|
| Notes   |
| The yearly average, indicates grading complies with BS EN 12620: 2002+A1 2008 (10/20) |

|                               |       |
|-------------------------------|-------|
| Yearly Average - Constituents |       |
| % Class 'X' material          | 0.10% |

**Compliant with WRAP Quality Protocol threshold for secondary aggregates.**



1. This is a certificate of conformity sheet for 2025.  
 2. The certificate uses the average of the data collected in 2025 from accredited geotechnical laboratory I2 analytical.